



**Planning, Development and Building Construction Division
Transportation, Infrastructure and Energy**

Tel 902 368 5060
Fax 902 368 0590
www.gov.pe.ca/
<http://www.gov.pe.ca>

PO Box 2000
Charlottetown
Prince Edward Island
Canada C1A 7N8

Addendum

Boiler Replacement Tyne Valley Youth Center 3980-19054

ADDENDUM # 002

Date : September 27, 2019

Page 1 of 1

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

Note: Please indicate this addendum number on the Contract Tender Form.

Item

Description

A – 2.1

Reference .4.1 Boiler Standard of Acceptance

**.1 Remove Standard of acceptance Taco Model # 1161 1/3 HP
Replace with: Standard of acceptance Taco Model # 1611 1/3 HP**

- End of Addendum -