



**Planning, Development and Building Construction Division
Transportation, Infrastructure and Energy**

Tel 902 368 5060
Fax 902 368 0590
www.gov.pe.ca/
<http://www.gov.pe.ca>

PO Box 2000
Charlottetown
Prince Edward Island
Canada C1A 7N8

Addendum

Ecole Francois-Buote Partial Roof Replacement Project Number: 160-20063

ADDENDUM # 1

Date: September 9, 2020

Page 1 of 1

The following amendment to the tender documents is effective immediately. This addendum shall form part of the contract documents.

Note: Please indicate this addendum number on the Contract Tender Form.

Item	Description
A - 1 - 1	Please note the tender closing is being extended to September 15, 2020 at 2:00 pm.
A - 1 - 2	Reference Specification Section 7J: <ol style="list-style-type: none">1. Delete item 4.a) Asphalt...2. Refer to item 4.c).1.4 – Add Vanguard 180 FS by Lexcor.3. Refer to item 4.c).3.2 – Delete reference to Class A.4. Refer to item 4.c).3.5 – Add Vanguard 250 TC by Lexcor5. Refer to item 4.i).1 – Flash-Tite Superdrain by Lexcor
A - 1 – 3	Any damage to existing landscaping caused by this project is to be repaired by the contractor to original condition.
A - 1 – 4	Where the flat roof meets the sloped section, continue the cover board up the vertical surface and torch the base sheet and cap sheet up the vertical surface and continue onto the sloped roof 300mm.
A - 1 – 5	Refer to drawing A2, Detail B – Delete reference to new metal flashing. Existing metal flashing to remain and be modified. Extend membrane flashings onto existing metal flashing.

- End of Addendum -