

1 ADDENDUM #3

All clauses set forth in the Bidding Documents, Contract Documents and General Requirements of the original Contract Documents shall apply to and govern this work. The addendum refers to changes and additions to the original Contract Documents and is to be read in conjunction with the same. All other parts of the original Contract Documents are to be considered as applying to the work of this Contract with the exceptions and changes as noted below.

1.1 DRAWINGS

- .1 Reference Drawing A1-001 Context Plan & Project Info:
 - .1 Reference Roof Type Schedule:
 - .1 Reference Type R2:
 - .1 Delete the following wording: "NEW 90mm RIGID INSULATION, (R21), REFER TO ROOF PLAN FOR TAPERED INSULATION, MECHANICALLY ATTACHED" and replace with the following: "NEW 165mm RIGID INSULATION (MIN. R37.5). REFER TO ROOF PLAN FOR TAPERED INSULATION, MECHANICALLY ATTACHED."
 - .2 Delete the following wording: "75mm RIGID INSULATION, R18 (EXISTING)".

END OF SECTION