

1 ADDENDUM #4

All clauses set forth in the Bidding Documents, Contract Documents and General Requirements of the original Contract Documents shall apply to and govern this work. The addendum refers to changes and additions to the original Contract Documents and is to be read in conjunction with the same. All other parts of the original Contract Documents are to be considered as applying to the work of this Contract with the exceptions and changes as noted below.

1.1 ADDENDA

.1 Reference Drawing M102 - Mechanical Details & Schedules:

- .1 Add "Louver Schedule" referenced on MSK-01, issued with and forming part of this addendum.

END OF SECTION

LOUVER SCHEDULE

TAG	BASIS OF DESIGN	TOTAL AREA (Sq. FT)	FREE AREA (Sq. FT)	HEIGHT (in)	WIDTH (in)	AIR DATA		NOTES
						AIRFLOW (CFM)	VELOCITY (FPM)	
L-1	VENTEX 2625	2.25	1.13	18	18	240	212	C/W MOTORIZED DAMPER TO FIT SIZE OF LOUVER, DAMPER TIED INTO NEW EXHAUST FANS INSTALLED ON ROOF OF EXISTING BUILDING. COORDINATE PAINT ON-SITE WITH OWNER