

## 1 ADDENDUM #6

ALL CLAUSES SET FORTH IN THE BIDDING DOCUMENTS, CONTRACT DOCUMENTS AND GENERAL REQUIREMENTS OF THE ORIGINAL CONTRACT DOCUMENTS SHALL APPLY TO AND GOVERN THIS WORK. THE ADDENDUM REFERS TO CHANGES AND ADDITIONS TO THE ORIGINAL CONTRACT DOCUMENTS AND IS TO BE READ IN CONJUNCTION WITH THE SAME. ALL OTHER PARTS OF THE ORIGINAL CONTRACT DOCUMENTS ARE TO BE CONSIDERED AS APPLYING TO THE WORK OF THIS CONTRACT WITH THE EXCEPTIONS AND CHANGES AS NOTED BELOW.

### 1.1 ADDENDA

- .1 Reference Addendum #5:  
Reference Appendix Item 1.3.1.1.2.1:
  - .1 Delete as wording "USG MARS-CLIMAPLUS #88185: and replace with the following:  
"Product: USG Mars - Climaplus  
Texture: Fine  
Size: 610 x 610 x 19, Item 86185  
NRC: 0.75, CAC: 35  
Fire Performance: Class A"
  - .2 **Clarification:**  
*This outlines more specific information for all acoustic ceiling tiles.*

### 1.2 APPENDICES

- .1 Reference Appendix 'A' - Material / Finish Schedule"
  - .1 Reference TAG "ACT-1 - Ceiling Tile"
    - .1 Reference Manufacturer / Supplier (Standard of Acceptance):
      - .1 Add "Armstrong" as an acceptable alternative.
    - .2 Reference Description / Finish/ Texture:
      - .1 Delete the following wording:  
~~"Product: Ultima High NRC  
15/16" Square Lay-In  
Size: Refer to drawings  
Thickness: 19mm  
NRC: 0.75  
CAC: 35  
Fire Performance: Class A  
Texture: Fine"~~  
  
and replace with the following:  
"Product: Ultima  
Texture: Fine  
Square Lay-In  
Size: 610 x 610 x 19, Item 1910  
NRC 0.75, CAC 35  
Fire Performance: Class A"
    - .3 **Clarification:**  
*This outlines more specific information for all acoustic ceiling tiles.*

END OF SECTION